

EC type examination certificate**EG-Baumusterprüfbescheinigung****CE-0085CL0214**Product Identification No.
Produkt-Identnummer**Field of Application****Anwendungsbereich**

EC Gas Appliances Directive (2009/142/EC)

EG-Gasgeräte-Richtlinie (2009/142/EG)

Distributor**Vertreiber**

BAXI S.p.A.

Via Trozzetti, 20, I-36061 Bassano del Grappa (VI)

Product Category**Produktart**

Boilers with flue systems: Condensing combi water heater (3204)

Product Description**Produktbezeichnung**

Wall hanging condensing combi water heater with full automatic burner control, gas/combustion-air ratio control and secondary heat exchanger

Model**Modell**

BOYLER CONDENS...

Countries of Destination**Bestimmungsländer**

AL, AT, BE, BG, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IT, LT, LU, LV, MK, NL, NO, PL, PT, RO, SE, SI, SK, TR

Test Reports**Prüfberichte**

supplement test: 15/029/3204/101 from 16.04.2015 (EBI)

Test Basis**Prüfgrundlagen**

EU/2009/142/EG (30.11.2009)

DIN EN 483 (01.06.2000)

DIN EN 677 (01.08.1998)

DIN EN 625 (01.10.1995)

DIN EN 15502-1 (01.10.2012)

DIN EN 15502-2/1 (01.01.2013)

File Number**Aktenzeichen**

15-0351-GEA

08.07.2015 Rie G-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EC Directive 2009/142/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EG-Richtlinie 2009/142/EG.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Elektrical Data
Elektrische Daten

230 V AC, 50 Hz, IPX5D

Appliance Categories Gerätekatégorien	Supply Pressures Versorgungsdrücke	Countries of Destination Bestimmungsländer	Remarks Bemerkungen
I2E(S)	20/25 mbar	BE	
I2H	20 mbar	DK	
I2N	20/25 mbar	BE	
I3P	37 mbar	BE	
II2E LwLs3P	20,20,13, 37 mbar	PL	
II2E3P	20, 37 mbar	LU	
II2ELL3P	20, 50 mbar	DE	
II2Esi3P	20/25, 37 mbar	FR	
II2H3P	20, 30 mbar	AT, EE, FI, LT, LV, NO, RO, SE, SI	
II2H3P	20, 37 mbar	CZ, ES, GB, GR, HR, IE, IT, PT, SK, TR	
II2H3P	20, 50 mbar	AT	
II2HM3P	20, 37 mbar	IT	
II2HS3P	25, 37 mbar	HU	
II2L3P	25, 37 mbar	NL	

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
BOYLER CONDENS 16	nominal heat output: 2,2...12,0 kW nominal heat input (Hi): 2,3...12,4 (drinking water: ...16,5) kW	
BOYLER CONDENS 24: BOYLER CONDENS+ 24	nominal heat output: 3,4...20,0 kW nominal heat input (Hi): 3,5...20,6 (drinking water: ...24,7) kW	
BOYLER CONDENS 33: BOYLER CONDENS+ 33	nominal heat output: 4,7...28,0 kW nominal heat input (Hi): 4,8...28,9 (drinking water: ...34,0) kW	

Hints of Utilization /Remarks**Verwendungshinweise / Bemerkungen**

flue types B23, C13, C33, C43, C53, C63, C83, C93, C13x, C33x, C43x, C53x, C63x, C83x, C93x: according to "installation manual BOYLER CONDENS..."

Additionally tested appliance categories, supply pressures and countries of destination:

CY: II2H3P (20, 30 mbar)

AL, BG, MK: II2H3P (20, 37 mbar)

In Albania and in Macedonia the CE-marking will be accepted as conformity approval if the Gas Appliance Directive (2009/142/EC) is transferred into national law by Albania respectively Macedonia.

EC type examination certificate

EG-Baumusterprüfbescheinigung

CE-0085CL0214Product Identification No.
Produkt-Identnummer**Field of Application**
*Anwendungsbereich*EC Efficiency Directive (92/42/EEC)
EG-Wirkungsgradrichtlinie (92/42/EEG)**Distributor**
*Vertreiber*BAXI S.p.A.
Via Trozzetti, 20, I-36061 Bassano del Grappa (VI)**Product Category**
Produktart

Boilers with flue systems: Condensing combi water heater (3204)

Product Description
Produktbezeichnung

Wall hanging condensing combi water heater with full automatic burner control, gas/combustion-air ratio control and secondary heat exchanger

Model
Modell

BOYLER CONDENS...

Type of Boiler
Heizkesseltyp

condensing boiler

Test Reports
Prüfberichte

supplement test: 15/029/3204/101 from 16.04.2015 (EBI)

Test Basis
Prüfgrundlagen

EU/92/42 (21.05.1992)

File Number
Aktenzeichen

15-0351-GWA

DVGW CERT GmbH

08.07.2015 Rie G-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH - recognized by the German Institute for Building Technology (DIBt) and notified at the European Commission as certification body for the EC Boiler Efficiency Directive

DVGW CERT GmbH - vom Deutschen Institut für Bautechnik (DIBt) nach dem Bauproduktengesetz anerkannte und bei der Europäischen Kommission benannte Zertifizierungsstelle für die EG-Heizkessel-Wirkungsgradrichtlinie

DIBt
ZP 42DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Energy Labelling Energieeffizienzkennzeichnung
BOYLER CONDENS 16	nominal heat output: 2,2...12,0 kW nominal heat input (Hi): 2,3...12,4 (drinking water: ...16,5) kW	****
BOYLER CONDENS 24: BOYLER CONDENS+ 24	nominal heat output: 3,4...20,0 kW nominal heat input (Hi): 3,5...20,6 (drinking water: ...24,7) kW	****
BOYLER CONDENS 33: BOYLER CONDENS+ 33	nominal heat output: 4,7...28,0 kW nominal heat input (Hi): 4,8...28,9 (drinking water: ...34,0) kW	****

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

The energy labelling can be used according to the actual regulations of the country of destination for the individual types. The above listed model was certified under the Product-Idenumber CE-0085CL0214 according to the Gas Appliance Directive (2009/142/EC).