

EC type examination certificate

EG-Baumusterprüfbescheinigung

CE-0085CM0128

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Gas Appliances Directive (2009/142/EC) <i>EG-Gasgeräte-Richtlinie (2009/142/EG)</i>
Distributor <i>Vertreiber</i>	BAXI S.p.A. Via Trozzetti, 20, I-36061 Bassano del Grappa (VI)
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing water heater (3202)
Product Description <i>Produktbezeichnung</i>	Wall hanging condensing water heater with full automatic burner control, gas/combustion-air ratio control and secondary heat exchanger
Model <i>Modell</i>	STAR CONDENS+...
Countries of Destination <i>Bestimmungsländer</i>	AL, AT, BE, BG, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IT, LT, LU, LV, MK, NL, NO, PL, PT, RO, SE, SI, SK, TR
Test Reports <i>Prüfberichte</i>	supplement test: 14/182/3204/147 from 27.03.2015 (EBI) supplement test: 15/030/3204/998 from 20.04.2015 (EBI)
Test Basis <i>Prüfgrundlagen</i>	EU/2009/142/EG (30.11.2009) DIN EN 15502-1 (01.10.2012) DIN EN 15502-2/1 (01.01.2013)

File Number 15-0335-GEA
Aktenzeichen

17.06.2015 Rie J-1/2

Date, issued by, Signer, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EC Directive 2009/142/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EG-Richtlinie 2009/142/EG.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Elektrical Data 230 V AC, 50 Hz, IPX5D
Elektrische Daten

Appliance Categories <i>Gerätekatégorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2E(S)	20/25 mbar	BE	
I3P	37 mbar	BE	
II2E Lw3P	20, 37 mbar	PL	
II2E3P	20, 50 mbar	LU	
II2Esi3P	20/25, 37 mbar	FR	
II2H3P	20, 30 mbar	DK, EE, FI, LT, LV, NO, RO, SE, SI	
II2H3P	20, 37 mbar	CZ, ES, GB, GR, HR, IE, IT, PT, SK, TR	
II2H3P	20, 50 mbar	AT	
II2HM3P	20, 37 mbar	IT	
II2HS3P	25, 37 mbar	HU	
II2L3P	25, 37 mbar	NL	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
STAR CONDENS+ 1.50	nominal heat output: 5,0...45,0 kW heat input (Hi): 5,1...46,3 kW	
STAR CONDENS+ 1.60	nominal heat output: 6,1...55,0 kW heat input (Hi): 6,3...56,6 kW	
STAR CONDENS+ 1.70	nominal heat output: 7,2...65,0 kW heat input (Hi): 7,4...66,9 kW	
STAR CONDENS+ 1.90	nominal heat output: 9,4...85,0 (natural gas); 12,2...85,0 (LPG) kW heat input - natural gas (Hi): 9,7...87,4 kW heat input - LPG (Hi): 12,5...87,4 kW	
STAR CONDENS+ 1.110	nominal heat output: 11,4...102,0 kW heat input (Hi): 11,7...104,9 kW	

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

flue types B23, B23P, C13, C33, C43, C53, C63, C83, C93: according to "installation manual STAR CONDENS+..."

Additionally tested appliance categories, supply pressures and countries of destination:

CY: II2H3P (20, 30 mbar)

AL, BG, MK: II2H3P (20, 37 mbar)

In Albania and Macedonia the CE-marking will be accepted as conformaty approval if the Gas Appliance Directive (2009/142/EC) is transferred into national law by Albania respectively Macedonia.

EC type examination certificate
EG-Baumusterprüfbescheinigung

CE-0085CM0128

Product Identification No.
 Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Efficiency Directive (92/42/EEC) EG-Wirkungsgradrichtlinie (92/42/EWG)
Distributor <i>Vertreiber</i>	BAXI S.p.A. Via Trozzetti, 20, I-36061 Bassano del Grappa (VI)
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing water heater (3202)
Product Description <i>Produktbezeichnung</i>	Wall hanging condensing water heater with full automatic burner control, gas/combustion-air ratio control and secondary heat exchanger
Model <i>Modell</i>	STAR CONDENS+...
Type of Boiler <i>Heizkesseltyp</i>	condensing boiler
Test Reports <i>Prüfberichte</i>	supplement test: 14/182/3204/147 from 27.03.2015 (EBI) supplement test: 15/030/3204/998 from 20.04.2015 (EBI)
Test Basis <i>Prüfgrundlagen</i>	EU/92/42 (21.05.1992)
File Number <i>Aktenzeichen</i>	15-0335-GWA

10028104-DE



17.06.2015 Rie J-1/2

Date, Issued by, Sheet, Head of Certification Body
 Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH - recognized by the German Institute for Building Technology (DIBt) and notified at the European Commission as certification body for the EC Boiler Efficiency Directive

DVGW CERT GmbH - vom Deutschen Institut für Bautechnik (DIBt) nach dem Bauproduktengesetz anerkannte und bei der Europäischen Kommission benannte Zertifizierungsstelle für die EG-Heizkessel-Wirkungsgradrichtlinie

DIBt
 ZP 42

DVGW CERT GmbH
 Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
 53123 Bonn

Tel. +49 228 91 88 - 888
 Fax +49 228 91 88 - 993

www.dvgw-cert.com
 info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Energy Labelling <i>Energieeffizienzkenzeichnung</i>
STAR CONDENS+ 1.50	nominal heat output: 5,0...45,0 kW heat input (Hi): 5,1...46,3 kW	****
STAR CONDENS+ 1.60	nominal heat output: 6,1...55,0 kW heat input (Hi): 6,3...56,6 kW	****
STAR CONDENS+ 1.70	nominal heat output: 7,2...65,0 kW heat input (Hi): 7,4...66,9 kW	****
STAR CONDENS+ 1.90	nominal heat output: 9,4...85,0 (natural gas); 12,2...85,0 (LPG) kW heat input - natural gas (Hi): 9,7...87,4 kW heat input - LPG (Hi): 12,5...87,4 kW	****
STAR CONDENS+ 1.110	nominal heat output: 11,4...102,0 kW heat input (Hi): 11,7...104,9 kW	****

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

The energy labelling can be used according to the actual regulations of the country of destination for the individual types. The above listed model was certified under the Product-Identnumber CE-0085CM0128 according to the Gas Appliance Directive (2009/142/EC).